



**2022 Drinking Water Quality Annual Report**  
**Facility No. 14-105-00001**



**Date Submitted: June 23, 2023**

# Table of Contents

<b>1.0 SYSTEM OVERVIEW AND DESCRIPTION.....</b>	<b>4</b>
<b>1.1 SUMMERLAND WATER SYSTEM .....</b>	<b>4</b>
<b>1.11 Supply .....</b>	<b>4</b>
<b>1.12 Water Treatment Plant.....</b>	<b>4</b>
<b>1.13 Water Distribution System.....</b>	<b>6</b>
<b>1.14 Wells.....</b>	<b>6</b>
<b>1.2 GARNETT VALLEY IRRIGATION “ONLY” SYSTEM.....</b>	<b>6</b>
<b>1.3 SUMMERLAND RODEO GROUNDS WATER SYSTEM.....</b>	<b>6</b>
<b>2.0 SYSTEM CLASSIFICATION AND OPERATOR CERTIFICATION .....</b>	<b>7</b>
<b>3.0 SOURCE SAMPLING.....</b>	<b>7</b>
<b>3.1 SAMPLE SCHEDULES.....</b>	<b>9</b>
<b>3.11 Summerland Water System – 2022 Sample Schedule.....</b>	<b>9</b>
<b>3.12 Summerland Water Treatment Plant – 2022 Sample Schedule.....</b>	<b>10</b>
<b>3.13 Rodeo Water System – 2022 Sample Schedule .....</b>	<b>10</b>
<b>4.0 BACTERIOLOGICAL SUMMARY .....</b>	<b>11</b>
<b>4.1 SUMMERLAND WATER SYSTEM .....</b>	<b>11</b>
<b>4.2 RODEO GROUNDS WATER SYSTEM.....</b>	<b>11</b>
<b>5.0 ADDITIONAL WATER QUALITY INFORMATION .....</b>	<b>11</b>
<b>5.1 COMPREHENSIVE SUMMARY .....</b>	<b>11</b>
<b>5.2 CHLORINE RESIDUAL .....</b>	<b>16</b>
<b>5.3 TURBIDITY.....</b>	<b>16</b>
<b>5.4 TRIHALOMETHANES &amp; HALOACETIC ACIDS.....</b>	<b>17</b>
<b>5.5 CRYPTOSPORIDIUM AND GIARDIA .....</b>	<b>18</b>
<b>5.6 GROSS ALPHA &amp; BETA .....</b>	<b>19</b>
<b>5.7 ALGAE.....</b>	<b>20</b>
<b>6.0 ANNUAL WATER CONSUMPTION .....</b>	<b>21</b>
<b>7.0 WATER QUALITY EVENTS .....</b>	<b>22</b>
<b>7.1 SUMMERLAND WATER SYSTEM .....</b>	<b>22</b>
<b>8.0 SYSTEM SHORTFALLS AND PROBLEMS.....</b>	<b>24</b>
<b>8.1 SUMMERLAND WATER SYSTEM .....</b>	<b>24</b>
<b>8.2 RODEO WATER SYSTEM .....</b>	<b>24</b>
<b>9.0 CAPITAL WORKS PLAN .....</b>	<b>25</b>
<b>9.1 COMPLETED PROJECTS IN 2022 .....</b>	<b>25</b>
<b>WATER TREATMENT PLANT .....</b>	<b>25</b>
<b>WATERSHED.....</b>	<b>25</b>
<b>WATER DISTRIBUTION SYSTEM.....</b>	<b>25</b>
<b>9.2 ANTICIPATED CAPITAL PROJECTS FOR 2023 .....</b>	<b>25</b>
<b>WATER TREATMENT PLANT .....</b>	<b>25</b>
<b>WATERSHED.....</b>	<b>25</b>
<b>WATER DISTRIBUTION SYSTEM.....</b>	<b>25</b>
<b>9.3 FUTURE CAPITAL PROJECTS .....</b>	<b>26</b>
<b>10.0 EMERGENCY RESPONSE PLAN .....</b>	<b>27</b>

**11.0 CROSS CONNECTION CONTROL (CCC)..... 27**  
    **11.1 CCC BYLAW 2358 .....27**  
**12.0 SUPERVISORY CONTROL AND DATA ACQUISITION (SCADA)..... 27**  
    **12.1 SCADA UPDATES .....28**  
    **12.2 FUTURE SCADA UPDATES .....28**

## **1.0 System Overview and Description**

The District of Summerland (DOS), municipal water supply is comprised of two separate drinking water systems that supply potable water to approximately 12,042 people based on the 2021 Census by Statistics Canada. The Summerland water system also referred to as the Trout Creek water system is the largest and currently satisfies greater than 99 percent of the District's potable water demands. The Rodeo Grounds water system is the smallest with only three connections. Construction completed towards the end of 2017 separated the water supply from Garnett Reservoir to an irrigation “only” system. All Garnett Valley residences are now part of the Summerland water system and receive domestic water from the water treatment plant.

### **1.1 Summerland Water System**

#### **1.11 Supply**

There are nine District-owned reservoirs throughout the 760 square kilometer Summerland watershed. These reservoirs include Thirsk, Headwaters #1, #2, #3, #4, Crescent, Whitehead, Isintok and Tsuh as shown in Figure 2. The Summerland water system is gravity fed from Trout Creek and utilizes this diversion as the main supply. This water diversion feeds, via an open channel flume, into the Summerland Reservoir that acts as a 68ML (million litre) settling and balancing pond.

Water leaving the Summerland reservoir passes through a coarse intake screen followed by a finer mesh-screening chamber to remove any large debris before entering the water treatment plant and irrigation system.

In 2010, the initial phase of separating the irrigation system from the domestic water system was completed. A 13MLD (million litre per day) capacity line in the upper Prairie Valley area was separated from the combined domestic/irrigation system and now serves as an irrigation-only piping system.

An additional phase of separation occurred during the Garnett Valley upgrade in 2017, section 1.2. The irrigation line from Garnett Dam extended east up Jones Flat road where the irrigation connections were removed from the Summerland potable water supply and connected to the Garnett Valley Irrigation System.


#### **1.12 Water Treatment Plant**

The water treatment process shown in Figure 1 consists of coagulation, flocculation, sedimentation, filtration and chlorine disinfection with a capacity of 76MLD. There are two ballasted floc ACTIFLO clarifiers and six dual media DUSENFLO filters. This was the first water treatment plant in British Columbia to utilize this process. Through the utilization of microsand in addition to coagulant and polymer, the weight of the floc and speed of formation is greatly increased. This allows for rapid settling to occur in a much smaller footprint than conventional treatment plants.

A designated waste tank collects wastewater from the treatment process. Submersible pumps lift the wastewater to two on-site settling ponds. Pumps lift the settled sludge to drying beds that are located near the Summerland landfill site.


The recycled supernatant from the settling ponds is gravity fed back to the treatment process. This innovative design involves recycling up to 10% of the supernatant back to the front of the process for re-treatment. This significantly improves the water use efficiency of the process and makes it the first water plant in Canada to

utilize this technology. The following graph indicates the monthly average volume of water recycled back to the raw water tank.



Historical sampling results indicate that recycled water contributes very little to the amount of coliforms, colour, turbidity, Cryptosporidium oocysts and Giardia cysts returned to the head of the plant. Lab results for the recycled water indicates better water quality characteristics than that of the raw water from Trout Creek.

The treatment plant design is in accordance with LEED Silver guidelines. This design capitalizes on natural energy sources by use of extensive natural light and the use of heat pumps to transfer energy from raw water. Rainwater is collected and infiltrated back into the ground in dry wells to reflect the predevelopment site condition. The landscaping of the site closely reflects native species and requires no supplementary irrigation.



**Figure 1 – Water Treatment Plant Schematic**

### **1.13 Water Distribution System**

The distribution system in ground piping ranges in size from 50mm to 1.37m in diameter, with a total combined length of approximately 216km. Thirteen pressure-reducing stations, twelve pumping stations and three in-ground storage tanks regulate system pressures ranging from 35 to 175psi at the consumer level.

### **1.14 Wells**

Two wells named TW<sub>3</sub> and TW<sub>5</sub> installed on the Summerland Rodeo Grounds property in 2003 serve as an emergency only supplemental water source when flows from Trout Creek are insufficient to meet system demands. The relatively small combined output of TW<sub>3</sub> and TW<sub>5</sub> was determined to be 66LPS (liters per second). Supplemental well water was not required in 2022.

## **1.2 Garnett Valley Irrigation “only” System**

The Garnett Valley Irrigation system is gravity fed utilizing Garnett Reservoir as the supply. Garnett Reservoir has an upper catchment area of 56 square kilometers, which also encompasses Eneas Reservoir. The reservoir is located on Eneas Creek but receives much of its water from underground springs.

## **1.3 Summerland Rodeo Grounds Water System**

The Summerland Rodeo Grounds is a small water system located on Bathville Road. There are three connections supplying water to the Rodeo Grounds facilities, caretakers’ residence and the Kettle Valley Railway station. A 2HP submersible pump supplies water to the system with a maximum pumping rate of 255LPM (liters per minute). The 150mm diameter well is located on the Rodeo Grounds property and is 54m deep.

## 2.0 System Classification and Operator Certification

The Environmental Operators Certification Program, EOCP, classifies both the District of Summerland’s water distribution system and water treatment plant as class IV systems where class I is the least complex and class IV is the most complex.

The District currently employs six full time staff members to operate and maintain the water treatment plant, water distribution system and upper reservoir water supply system. Water Supply Technician’s certifications range from levels I to IV in both water distribution and water treatment.

<b>Employee</b>	<b>Certification #</b>	<b>Level</b>	<b>Goals</b>
Shawn Hughes	1510	WD IV, WT I	N/A
Matthew Lee	7058	WD I, WT IV	N/A
Sheree Lancaster	4020	WD III, WT IV	WD IV
Alex Bellemore	9357	WD II, WT IV	WD III
Evan Sorensen	1439	WT II, WD I	WT III & WD II
Kyra Marsden	156247	WT-1	WT II & WD I


Operators maintain EOCP certifications through various accredited training opportunities. Future certification plans include upgrading operators to higher levels.

## 3.0 Source Sampling

Summerland’s watersheds combined encompasses approximately 815 square kilometers. Within this boundary, the DOS owns and operates 12 water storage reservoirs as shown in Figure 2. Various other lakes and tributaries also contribute to the water supply on a seasonal basis. Due to the size and layout of the watershed, source sampling is limited. The Summerland Reservoir is located approximately 300m east, and hydraulically down gradient of the Summerland Landfill. Due to this proximity, additional sampling is a requirement of the Summerland Landfill Operating Certificate MR15275, issued under the provisions of the Environmental Management Act. Sample collection from specified monitoring wells and the Summerland reservoir is scheduled every three months, or quarterly. Samples are submitted to ALS Environmental Lab in Burnaby for analysis.

In addition to analysis of various parameters, water levels are recorded from 18 monitoring wells and the Summerland Reservoir on a bi-weekly to monthly basis. SNC Lavalin Inc. presented the data in the 2022 DOS Landfill Annual Water Quality Report. In summary of this report, the Landfill leachate did not negatively affect water quality in the Summerland Reservoir.





**Figure 2 - District of Summerland Watershed Map**



### 3.1 Sample Schedules

A sample schedule is used as a guideline for sampling events throughout the year. The following tables indicate the location and approximate timing for sample collection. Depending on the type of analysis, these locations may vary from source water before treatment to locations ranging from the first consumer to the distribution system ends.

#### 3.11 Summerland Water System – 2022 Sample Schedule

Summerland System	LAB	January	February	March	April	May	June	July	August	September	October	November	December
<b>Comprehensive</b> Pump House #6 – <i>Includes TOC</i>	CARO Kelowna				SA				SA				
<b>Comprehensive – Pretreatment</b> Summerland Reservoir Raw at WTP Lab tap	CARO Kelowna				SA				SA				
<b>Comprehensive - Watershed</b> Headwaters #1 Outlet, Thirsk Outlet, Trout Creek Raw at Intake, Isintok Outlet. <i>Includes TOC, Total P, Total dissolved P, TKN, Total Ammonia as N.</i>	CARO Kelowna								A				
<b>Algae - Watershed</b> HW#1, Thirsk, Garnet Valley (Early August)	CARO Kelowna								A				
<b>Algae – Pretreatment</b> Summerland Reservoir Raw at WTP Lab tap (quarterly through 2022 then adjust accordingly)	CARO Kelowna		Q			Q			Q			Q	
<b>Lead &amp; Copper – Distribution First Draw &amp; Plus 5 min</b> Two locations in Distribution	CARO Kelowna				SA				SA				
<b>E.coli</b> Trout Creek, (Up&Dn Stream of Dark Creek inflow) Dark Creek (Above & Below Cattleguard & Mailboxes)	CARO Kelowna						SA					SA	
<b>THMs</b> Pump House #6	CARO Kelowna	Q			Q			Q			Q		
<b>HAAs</b> Pump House #6	CARO Kelowna	Q			Q			Q			Q		
<b>Crypto/Giardia</b> Trout Creek Raw & WTP Recycle	CARO Richmond	M	M	M	M	M	M	M	M	M	M	M	M
<b>Total coliforms and E. coli</b> Various locations in Distribution	CARO Kelowna	W	W	W	W	W	W	W	W	W	W	W	W
<b>Turbidity</b> Various locations in Distribution	In House	W	W	W	W	W	W	W	W	W	W	W	W
<b>Chlorine Residuals</b> Various locations in Distribution	In House	W	W	W	W	W	W	W	W	W	W	W	W
<b>Gross Alpha &amp; Beta</b> Trout Creek Raw	CARO Kelowna									A			

\*W – WEEKLY M – MONTHLY Q – QUARTERLY SA – SEMI ANNUALLY A - ANNUALLY\*

### 3.12 Summerland Water Treatment Plant – 2022 Sample Schedule

Water Treatment Plant	January	February	March	April	May	June	July	August	September	October	November	December
<b>Turbidity</b> Trout Creek Raw, WTP Recycle, Waste, Actiflo(s), Treated water at PH#2	D	D	D	D	D	D	D	D	D	D	D	D
<b>Hardness and Alkalinity</b> Trout Creek Treated	W	W	W	W	W	W	W	W	W	W	W	W
<b>pH</b> Trout Creek Raw, WTP Recycle, Waste, Actiflo(s), Treated water at PH#2	D	D	D	D	D	D	D	D	D	D	D	D
<b>True Colour</b> Trout Creek Raw, WTP Recycle, Actiflo(s)	D	D	D	D	D	D	D	D	D	D	D	D
<b>True Colour</b> Treated water at PH#2	W	W	W	W	W	W	W	W	W	W	W	W
<b>Apparent Colour</b> Treated water at PH#2	D	D	D	D	D	D	D	D	D	D	D	D
<b>Apparent Colour</b> Trout Creek Raw	W	W	W	W	W	W	W	W	W	W	W	W
<b>UV Transmittance</b> Trout Creek Raw, Actiflo(s), Treated water at PH#2	D	D	D	D	D	D	D	D	D	D	D	D
<b>Aluminum</b> Treated water at PH#2	W	W	W	W	W	W	W	W	W	W	W	W
<b>TSS</b> WTP Recycle & Waste	W	W	W	W	W	W	W	W	W	W	W	W

\*W – WEEKLY D – DAILY

### 3.13 Rodeo Water System – 2022 Sample Schedule

Rodeo System	LAB	Jan	Febr	Mar	Apr	May	June	Jul	Aug	Sept	Octo	Nov	Dece
<b>Comprehensive</b> Lodge	CARO Kelowna				S A				S A				
<b>Total coliforms and E. coli</b> Lodge	CARO Kelowna	W	W	W	W	W	W	W	W	W	W	W	W
<b>Turbidity</b> Lodge	In House	W	W	W	W	W	W	W	W	W	W	W	W
<b>Gross Alpha &amp; Beta</b> Lodge	CARO Kelowna									A			
<b>Iron</b> Lodge	In House	W	W	W	W	W	W	W	W	W	W	W	W
<b>Manganese</b> Lodge	In House	M	M	M	M	M	M	M	M	M	M	M	M
<b>pH</b> Lodge	In House	W	W	W	W	W	W	W	W	W	W	W	W

\*W – WEEKLY M – MONTHLY SA – SEMI ANNUALLY A - ANNUALLY\*

## 4.0 Bacteriological Summary

The DOS must complete a minimum bacteriological sampling frequency of four samples per week in the Summerland water system and a frequency of four samples per month in the Rodeo water system. The collection of water samples are from predetermined locations throughout the town boundaries.

### 4.1 Summerland Water System

The Summerland water distribution system is classified by Interior Health as a water system with 301-10,000 connections. Sample sites are located from the middle to the end of the distribution system in alternating locations. An average of four samples are collected weekly and shipped to Caro Analytical.

Two hundred and four bacteriological samples were collected from the Summerland water system throughout the year and submitted to Caro Analytical for analysis. All treated water samples were absent for Total Coliforms and *E-coli*.

### 4.2 Rodeo Grounds Water System

The Rodeo Grounds Water System is classified by Interior Health as a small water system with 14 or less connections. Sample sites are identified as the Lodge and the Kettle Valley Railway station (KVR). One sample is collected weekly from the Rodeo Grounds water system and submitted to Caro Analytical.

There were fifty-one samples collected from the Summerland Rodeo Grounds water system in 2022. All Rodeo Lodge water samples were absent for Total Coliforms and E-coli.

## 5.0 Additional Water Quality Information

### 5.1 Comprehensive Summary

Comprehensive water analysis was performed on both water systems in the spring and fall of 2022 to ensure compliance with the Guidelines for Canadian Drinking Water Quality (GCDWQ). Parameters include metals, nutrients, bacteria, anions, and aesthetic objectives including colour, taste and odour. Monitoring of source water included an annual set of samples collected from the low-level outlets of Thirsk Reservoir and Headwaters #1 Reservoir.

#### **Glossary of Terms:**

GCDWQ - Guidelines for Canadian Drinking Water Quality  
MRL - Method Reporting Limit  
MAC - Maximum Acceptable Concentration  
OG - Operational Guideline  
AO - Aesthetic Objective  
CFU/100mL - Colony Forming Units per 100 millilitres

mg/L - Milligrams per Litre  
CU - Colour Units  
µS/cm - Microsiemens per Centimeter  
NTU - Nephelometric Turbidity Units  
pH units - pH <7 = acidic, pH >7 = basic

## 5.11 Summerland Water System – Trout Creek Raw

### Caro Analytical Services - Lab Summary Summerland System - Trout Creek Raw

Month/Year	April 2022	MRL	GCDWQ	Units
<b>Anions</b>				
Chloride	2.47	0.10	AO ≤ 250	mg/L
Fluoride	<0.10	0.10	MAC = 1.5	mg/L
Nitrate (as N)	<0.010	0.010	MAC = 10	mg/L
Nitrite (as N)	<0.010	0.010	MAC = 1	mg/L
Sulfate	6.6	1.0	AO ≤ 500	mg/L
<b>General Parameters</b>				
Alkalinity, Total (as CaCO <sub>3</sub> )	67.3	1.0	N/A	mg/L
Alkalinity, Phenolphthalein (as CaCO <sub>3</sub> )	<1.0	1.0	N/A	mg/L
Alkalinity, Bicarbonate (as CaCO <sub>3</sub> )	67.3	1.0	N/A	mg/L
Alkalinity, Carbonate (as CaCO <sub>3</sub> )	<1.0	1.0	N/A	mg/L
Alkalinity, Hydroxide (as CaCO <sub>3</sub> )	<1.0	1.0	N/A	mg/L
Colour, True	22	5.0	AO ≤ 15	CU
Conductivity (EC)	134	2.0	N/A	µS/cm
Cyanide, Total	<0.0020	0.0020	MAC = 0.2	mg/L
pH	7.51	0.10	7-10.5	pH units
Temperature, at pH	22.5		N/A	°C
Turbidity	0.90	0.10	OG <0.1	NTU
<b>Calculated Parameters</b>				
Hardness, Total (as CaCO <sub>3</sub> )	61.7	0.500	N/A	mg/L
Langlier Index	-0.8	-5.0	N/A	-
Solids, Total Dissolved (calc)	78.9	1.00	N/A	mg/L
<b>Total Metals</b>				
Aluminum, total	0.0455	0.0050	OG <0.1	mg/L
Antimony, total	<0.00020	0.00020	MAC = 0.006	mg/L
Arsenic, total	<0.00050	0.00050	MAC = 0.01	mg/L
Barium, total	0.0422	0.0050	MAC = 1	mg/L
Boron, total	<0.0050	0.0050	MAC = 5	mg/L
Cadmium, total	<0.000010	0.000010	MAC = 0.005	mg/L
Calcium, total	18.8	0.20	N/A	mg/L
Chromium, total	0.001	0.00050	MAC = 0.05	mg/L
Cobalt, total	<0.00010	0.00010	N/A	mg/L
Copper, total	0.00245	0.00040	MAC = 2	mg/L
Iron, total	0.142	0.010	AO ≤ 0.3	mg/L
Lead, total	<0.00020	0.00020	MAC = 0.01	mg/L
Magnesium, total	3.57	0.010	N/A	mg/L
Manganese, total	0.0193	0.00020	AO ≤ 0.05	mg/L
Mercury, total	<0.000010	0.000010	MAC = 0.001	mg/L
Molybdenum, total	0.00298	0.00010	N/A	mg/L
Nickel, total	0.00042	0.00040	N/A	mg/L
Potassium, total	1.5	0.10	N/A	mg/L
Selenium, total	<0.00050	0.00050	MAC = 0.05	mg/L
Sodium, total	4.97	0.10	AO ≤ 200	mg/L
Strontium, total	0.264	0.0010	N/A	mg/L
Uranium, total	0.00282	0.000020	MAC = 0.02	mg/L
Zinc, total	0.0059	0.0040	AO ≤ 5	mg/L
<b>Microbiological Parameters</b>				
Coliforms, Total	14	1	MAC = None Detected	CFU/100mL
E.coli	<1.0	1	MAC = None Detected	CFU/100mL

## 5.12 Summerland Water System – Pump House #6

### Caro Analytical Services - Lab Summary Summerland System - Pump House #6

Month/Year	April 2022	August 2022	MRL	GCDWQ	Units
<b>Anions</b>					
Chloride	12.1	14.1	0.10	AO ≤ 250	mg/L
Fluoride	<0.10	<0.10	0.10	MAC = 1.5	mg/L
Nitrate (as N)	<0.010	<0.010	0.010	MAC = 10	mg/L
Nitrite (as N)	<0.010	<0.010	0.010	MAC = 1	mg/L
Sulfate	6.6	3.6	1.0	AO ≤ 500	mg/L
<b>General Parameters</b>					
Alkalinity, Total (as CaCO <sub>3</sub> )	64.8	56.9	1.0	N/A	mg/L
Alkalinity, Phenolphthalein (as CaCO <sub>3</sub> )	<1.0	<1.0	1.0	N/A	mg/L
Alkalinity, Bicarbonate (as CaCO <sub>3</sub> )	64.8	56.9	1.0	N/A	mg/L
Alkalinity, Carbonate (as CaCO <sub>3</sub> )	<1.0	<1.0	1.0	N/A	mg/L
Alkalinity, Hydroxide (as CaCO <sub>3</sub> )	<1.0	<1.0	1.0	N/A	mg/L
Colour, True	<5.0	<5.0	5.0	AO ≤ 15	CU
Conductivity (EC)	161	144	2.0	N/A	µS/cm
Cyanide, Total	<0.0020	<0.0020	0.0020	MAC = 0.2	mg/L
pH	7.60	7.30	0.10	7-10.5	pH units
Temperature, at pH	22.3	23.3		N/A	°C
Turbidity	<0.10	<0.10	0.10	OG <0.1	NTU
<b>Calculated Parameters</b>					
Total Trihalomethanes	N/A	0.056	0.00400	MAC = 0.1	mg/L
Hardness, Total (as CaCO <sub>3</sub> )	61.6	48.5	0.500	N/A	mg/L
Langlier Index	-0.7	-1.4	-5.0	N/A	-
Solids, Total Dissolved (calc)	91.8	80.1	1.00	N/A	mg/L
<b>Total Metals</b>					
Aluminum, total	0.0192	0.0300	0.0050	OG <0.1	mg/L
Antimony, total	<0.00020	<0.00020	0.00020	MAC = 0.006	mg/L
Arsenic, total	<0.00050	<0.00050	0.00050	MAC = 0.01	mg/L
Barium, total	0.0387	0.0317	0.0050	MAC = 1	mg/L
Boron, total	<0.0500	<0.0500	0.0050	MAC = 5	mg/L
Cadmium, total	<0.000010	<0.000010	0.000010	MAC = 0.005	mg/L
Calcium, total	19.2	15.3	0.20	N/A	mg/L
Chromium, total	<0.00050	<0.00050	0.00050	MAC = 0.05	mg/L
Cobalt, total	<0.00010	<0.00010	0.00010	N/A	mg/L
Copper, total	0.00292	0.00285	0.00040	MAC = 2	mg/L
Iron, total	<0.010	<0.010	0.010	AO ≤ 0.3	mg/L
Lead, total	<0.00020	<0.00020	0.00020	MAC = 0.01	mg/L
Magnesium, total	3.32	2.47	0.010	N/A	mg/L
Manganese, total	0.00159	0.00128	0.00020	AO ≤ 0.05	mg/L
Mercury, total	<0.000040	<0.000010	0.000010	MAC = 0.001	mg/L
Molybdenum, total	0.0028	0.00255	0.00010	N/A	mg/L
Nickel, total	<0.00040	<0.00040	0.00040	N/A	mg/L
Potassium, total	1.48	1.25	0.10	N/A	mg/L
Selenium, total	<0.00050	<0.00050	0.00050	MAC = 0.05	mg/L
Sodium, total	9.64	8.62	0.10	AO ≤ 200	mg/L
Strontium, total	0.284	0.198	0.0010	N/A	mg/L
Uranium, total	0.000773	0.000190	0.000020	MAC = 0.02	mg/L
Zinc, total	<0.0040	<0.0040	0.0040	AO ≤ 5	mg/L
<b>Volatile Organic Compounds (VOC)</b>					
Bromodichloromethane	N/A	0.0037	0.0010	N/A	mg/L
Bromoform	N/A	<0.0010	0.0010	N/A	mg/L
Chloroform	N/A	0.0523	0.0010	N/A	mg/L
Dibromochloromethane	N/A	<0.0010	0.0010	N/A	mg/L
Surrogate: Toluene-d8	N/A	108	70-130%		%
Surrogate: 4-Bromofluorobenzene	N/A	98	70-130%		%
<b>Microbiological Parameters</b>					
Coliforms, Total	<1	<1	1	MAC = None Detected	CFU/100mL
E.coli	<1	<1	1	MAC = None Detected	CFU/100mL

## 5.13 Rodeo Water System

### Caro Analytical Services - Lab Summary

#### Rodeo System - Lodge

Month/Year	April 2022	August 2022	MRL	GCDWQ	Units
<b>Anions</b>					
Chloride	2.14	2.14	0.10	AO ≤ 250	mg/L
Fluoride	0.14	0.14	0.10	MAC = 1.5	mg/L
Nitrate (as N)	0.211	0.197	0.010	MAC = 10	mg/L
Nitrite (as N)	<0.010	<0.010	0.010	MAC = 1	mg/L
Sulfate	12.1	11.5	1.0	AO ≤ 500	mg/L
<b>General Parameters</b>					
Alkalinity, Total (as CaCO <sub>3</sub> )	174	174	1.0	N/A	mg/L
Alkalinity, Phenolphthalein (as CaCO <sub>3</sub> )	<1.0	<1.0	1.0	N/A	mg/L
Alkalinity, Bicarbonate (as CaCO <sub>3</sub> )	174	174	1.0	N/A	mg/L
Alkalinity, Carbonate (as CaCO <sub>3</sub> )	<1.0	<1.0	1.0	N/A	mg/L
Alkalinity, Hydroxide (as CaCO <sub>3</sub> )	<1.0	<1.0	1.0	N/A	mg/L
Colour, True	<5.0	<5.0	5.0	AO ≤ 15	CU
Conductivity (EC)	311	320	2.0	N/A	µS/cm
Cyanide, Total	<0.0020	<0.0020	0.0020	MAC = 0.2	mg/L
pH	8.07	8.2	0.10	7-10.5	pH units
Temperature, at pH	22.3	23.8		N/A	°C
Turbidity	0.16	0.30	0.10	OG <0.1	NTU
<b>Calculated Parameters</b>					
Hardness, Total (as CaCO <sub>3</sub> )	151	143	0.500	N/A	mg/L
Langlier Index	0.5	0.4	-5.0	N/A	-
Solids, Total Dissolved (calc)	191	186	1.00	N/A	mg/L
<b>Total Metals</b>					
Aluminum, total	<0.0050	<0.0050	0.0050	OG <0.1	mg/L
Antimony, total	<0.00020	<0.00020	0.00020	MAC = 0.006	mg/L
Arsenic, total	<0.00050	<0.00050	0.00050	MAC = 0.01	mg/L
Barium, total	0.0701	0.0648	0.0050	MAC = 1	mg/L
Boron, total	<0.0500	<0.0500	0.0050	MAC = 5	mg/L
Cadmium, total	<0.000010	<0.000010	0.000010	MAC = 0.005	mg/L
Calcium, total	46.8	44.4	0.20	N/A	mg/L
Chromium, total	0.00069	0.00065	0.00050	MAC = 0.05	mg/L
Cobalt, total	<0.00010	<0.00010	0.00010	N/A	mg/L
Copper, total	0.0174	0.0208	0.00040	MAC = 2	mg/L
Iron, total	0.012	0.024	0.010	AO ≤ 0.3	mg/L
Lead, total	<0.00020	<0.00020	0.00020	MAC = 0.01	mg/L
Magnesium, total	8.32	7.84	0.010	N/A	mg/L
Manganese, total	0.00020	0.00072	0.00020	AO ≤ 0.05	mg/L
Mercury, total	<0.000010	<0.000010	0.000010	MAC = 0.001	mg/L
Molybdenum, total	0.00756	0.00685	0.00010	N/A	mg/L
Nickel, total	<0.00040	<0.00040	0.00040	N/A	mg/L
Potassium, total	3.05	2.82	0.10	N/A	mg/L
Selenium, total	<0.00050	<0.00050	0.00050	MAC = 0.05	mg/L
Sodium, total	11.4	10.1	0.10	AO ≤ 200	mg/L
Strontium, total	0.435	0.394	0.0010	N/A	mg/L
Uranium, total	0.00874	0.00794	0.000020	MAC = 0.02	mg/L
Zinc, total	0.0051	<0.0040	0.0040	AO ≤ 5	mg/L
<b>Microbiological Parameters</b>					
Coliforms, Total	<1	<1	1	MAC = None Detected	CFU/100mL
E.coli	<1	<1	1	MAC = None Detected	CFU/100mL

## 5.14 Source Water

### Caro Analytical Services - Lab Summary

#### Summerland System Source Water

	Headwaters #1 Reservoir Low Level Outlet	Thirsk Reservoir Low Level Outlet	Isintok Reservoir Low Level Outlet	MRL	GCDWQ	Units
<b>Month/Year</b>	<b>August 2022</b>	<b>August 2022</b>	<b>August 2022</b>			
<b>Anions</b>						
Chloride	0.28	0.51	0.11	0.10	AO ≤ 250	mg/L
Fluoride	<0.10	<0.10	<0.10	0.10	MAC = 1.5	mg/L
Nitrate (as N)	<0.010	<0.010	0.016	0.010	MAC = 10	mg/L
Nitrite (as N)	<0.010	<0.010	<0.010	0.010	MAC = 1	mg/L
Sulfate	3.4	2.7	<1.0	1.0	AO ≤ 500	mg/L
<b>General Parameters</b>						
Alkalinity, Total (as CaCO <sub>3</sub> )	56.4	42.2	13.6	1.0	N/A	mg/L
Alkalinity, Phenolphthalein (as CaCO <sub>3</sub> )	<1.0	<1.0	<1.0	1.0	N/A	mg/L
Alkalinity, Bicarbonate (as CaCO <sub>3</sub> )	56.4	42.2	13.6	1.0	N/A	mg/L
Alkalinity, Carbonate (as CaCO <sub>3</sub> )	<1.0	<1.0	<1.0	1.0	N/A	mg/L
Alkalinity, Hydroxide (as CaCO <sub>3</sub> )	<1.0	<1.0	<1.0	1.0	N/A	mg/L
Ammonia, Total (as N)	0.172	0.054	<0.050	0.050	N/A	mg/L
Carbon, Total Organic	5.30	8.80	7.39	0.5	N/A	mg/L
Colour, True	14	44	55	5.0	AO ≤ 15	CU
Conductivity (EC)	98.4	79.3	29.8	2.0	N/A	µS/cm
Cyanide, Total	<0.0020	<0.0020	<0.0020	0.0020	MAC = 0.2	mg/L
pH	7.45	7.43	6.96	0.10	7-10.5	pH units
Phosphorus, Total (as P)	0.0120	0.0161	0.0176	0.050	N/A	mg/L
Phosphorus, Total Dissolved	0.0064	0.0130	0.0129	0.050	N/A	mg/L
Temperature, at pH	21.9	22.4	21.8		N/A	°C
Turbidity	1.06	1.22	1.73	0.10	OG <0.1	NTU
<b>Calculated Parameters</b>						
Hardness, Total (as CaCO <sub>3</sub> )	43.1	35.7	12.6	0.500	N/A	mg/L
Langlier Index	-1.3	-1.5	-2.9	-5.0	N/A	-
Solids, Total Dissolved (calc)	57.6	45.7	15.5	1.00	N/A	mg/L
<b>Total Metals</b>						
Aluminum, total	0.0175	0.0649	0.2070	0.0050	OG <0.1	mg/L
Antimony, total	<0.00020	<0.00020	<0.00020	0.00020	MAC = 0.006	mg/L
Arsenic, total	<0.00050	<0.00050	<0.00050	0.00050	MAC = 0.01	mg/L
Barium, total	0.0144	0.0293	0.0109	0.0050	MAC = 1	mg/L
Boron, total	<0.0500	<0.0500	<0.0500	0.0050	MAC = 5	mg/L
Cadmium, total	<0.000010	<0.000010	<0.000010	0.000010	MAC = 0.005	mg/L
Calcium, total	14.6	11.4	3.87	0.20	N/A	mg/L
Chromium, total	0.00069	<0.00050	<0.00050	0.00050	MAC = 0.05	mg/L
Cobalt, total	<0.00010	0.00010	0.00015	0.00010	N/A	mg/L
Copper, total	0.00064	0.00138	0.00148	0.00040	MAC = 2	mg/L
Iron, total	0.065	0.155	0.308	0.010	AO ≤ 0.3	mg/L
Lead, total	<0.00020	<0.00020	<0.00020	0.00020	MAC = 0.01	mg/L
Magnesium, total	1.60	1.76	0.71	0.010	N/A	mg/L
Manganese, total	0.00917	0.0165	0.0594	0.00020	AO ≤ 0.05	mg/L
Mercury, total	<0.000010	<0.000010	<0.000010	0.000010	MAC = 0.001	mg/L
Molybdenum, total	0.00150	0.00183	0.00117	0.00010	N/A	mg/L
Nickel, total	<0.00040	<0.00040	<0.00040	0.00040	N/A	mg/L
Potassium, total	1.13	0.97	0.79	0.10	N/A	mg/L
Selenium, total	<0.00050	<0.00050	<0.00050	0.00050	MAC = 0.05	mg/L
Sodium, total	2.22	2.64	1.69	0.10	AO ≤ 200	mg/L
Strontium, total	0.0853	0.131	0.0295	0.0010	N/A	mg/L
Uranium, total	0.000048	0.000855	0.000273	0.000020	MAC = 0.02	mg/L
Zinc, total	<0.0040	<0.0040	<0.0040	0.0040	AO ≤ 5	mg/L
<b>Microbiological Parameters</b>						
Coliforms, Total	276	>2420	435	1	MAC = None Detected	CFU/100mL
E.coli	2	<1	<1	1	MAC = None Detected	CFU/100mL



## **5.2 Chlorine Residual**

Treated water is monitored continuously for free chlorine residual by on-line HACH/ProMinent analyzers at the water treatment plant and within the distribution system. Telephone and radio alarms alert operators if levels deviate from desired set points. To ensure output accuracy, chlorine analyzers are routinely calibrated and maintained.

As set out in the annual sample schedule, various sample points are tested for free chlorine residual weekly throughout the water distribution system. The HACH Pocket Colorimeter II is used to test chlorine residual, as it is both rugged and portable. The colorimeters are serviced and calibrated annually by a certified HACH technician for quality assurance.

There are thirteen sampling locations throughout the distribution system with pump house #2 located at the beginning of the system and monitored daily. The rest of the sample sites are located between the middle and the ends of the distribution system.

## **5.3 Turbidity**

### **5.31 Summerland Water System**

Raw water is monitored continuously with a Hach Surface Scatter 7sc Turbidimeter and trended on a 24-hour basis. A grab sample is also collected daily and analyzed in house with the Hach 2100Q for comparison. The meter is calibrated monthly or as required based on the readings. In 2022, daily raw water grab samples for turbidity ranged from a low of 0.54 NTU on January 30<sup>th</sup> to a high of 17.8 NTU on August 14<sup>th</sup>.

Recycled water is monitored continuously for turbidity with a HACH solitax sc turbidimeter and trended on SCADA. The turbidity for recycled water ranged from a low of 0.19 NTU during the month of February to a high of 2.39 NTU during the month of July.

Treated water is monitored continuously with Hach 5300sc turbidimeters at the six filter outlets prior to the clearwell and trended on SCADA. The annual average turbidity of treated water leaving the water treatment plant to distribution was 0.02 NTU.

In addition to the continuous on-line monitoring of treated water leaving the plant, daily grab samples from PH #2, the first point of distribution, ranged from a low of 0.07 NTU to a high of 0.31 NTU throughout the year. Turbidity is monitored daily in the distribution system with a portable HACH 2100Q and continuously with a Hach 5300 sc. A certified HACH technician services and calibrates the meter annually for quality assurance.

### **5.32 Rodeo Water System**

Rodeo Grounds turbidity is monitored weekly from the Lodge and/or the Kettle Valley Railway Station. Grab samples ranged from 0.18 NTU on August 29<sup>th</sup> to 0.91 NTU on December 5<sup>th</sup>. Occasional system flushing is required during periods of very low demand in order to regenerate the well with fresh water.

## 5.4 Trihalomethanes & Haloacetic Acids

The DOS must complete a minimum sampling frequency of four samples per year in the water distribution system for total Trihalomethanes (THMs) and for Haloacetic acids (HAAs).

Based on the Canadian Drinking Water Guideline for THMs, the maximum acceptable concentration (MAC) is 0.10mg/L, expressed as a running annual average of quarterly samples and the MAC for HAAs is 0.08mg/L. The sample location for the Summerland water system is pump house #6 located on Simpson Road and samples were submitted to Caro Analytical for analysis.

The average annual concentration of THMs was 0.0698mg/L.

The average annual concentration of HAAs was 0.0543mg/L.

### Trihalomethane (THMs) Lab Results Caro Analytical Services, Kelowna BC

#### Pump House #6

2022	Total Trihalomethanes, mg/L
February 8	0.0480
May 9	0.0773
August 15	0.0560
November 7	0.0978
<i>Minimum</i>	0.0480
<i>Maximum</i>	0.0978
<i>Average</i>	0.0698

### Haloacetic Acids (HAAs) Lab Results Caro Analytical Services, Kelowna BC

#### Pump House #6

2022	Total Haloacetic Acids, mg/L
February 8	0.0448
May 9	0.0721
August 15	0.0447
November 7	0.0557
<i>Minimum</i>	0.0447
<i>Maximum</i>	0.0721
<i>Average</i>	0.0543

## 5.5 Cryptosporidium and Giardia

Cryptosporidium and Giardia performance monitoring locations include raw water and recycled wastewater supernatant. Raw water is collected directly from the piping to the raw water tank and is thoroughly flushed prior to sample collection. Recycled supernatant is collected from the piping from the settling ponds and also thoroughly flushed prior to sample collection.

The following data includes the reported count per 100L volume of water.



### Cryptosporidium and Giardia Lab Results Caro Analytical Services, Kelowna BC

Date	Trout Creek Raw		WTP Recycle	
	Cryptosporidium species Oocysts/100L	Giardia species Cysts/100L	Cryptosporidium species Oocysts/100L	Giardia species Cysts/100L
<b>11-Jan-22</b>	0	1	0	0
<b>16-Feb-22</b>	2	52	0	0
<b>24-Mar-22</b>	0	4	0	0
<b>6-Apr-22</b>	3	65	0	0
<b>2-May-22</b>	2	11	0	0
<b>1-Jun-22</b>	0	0	0	0
<b>7-Jul-22</b>	1	22	0	1
<b>8-Aug-22</b>	2	71	1	2
<b>12-Sept-22</b>	0	0	0	0
<b>3-Oct-22</b>	0	218	10	9
<b>7-Nov-22</b>	28	10	0	0
<b>6-Dec-22</b>	0	88	0	0
<b>Average</b>	3	45	1	1



## 5.6 Gross Alpha & Beta

To assess the level of radionuclides in drinking water, raw water samples are submitted annually to Caro Analytical Services for analysis of gross alpha and beta. The tests are cost-effective screening tools used to determine whether further isotope-specific analysis for radium or uranium is necessary. Samples from both drinking water systems were collected at the source.

### 5.61 Summerland Water System

			
TEST RESULTS			
REPORTED TO PROJECT	Summerland, District of Summerland System	WORK ORDER REPORTED	22K0165 2022-11-14 13:05
Analyte	Result	Guideline	RL Units Analyzed Qualifier
<b>Trout Creek Raw (22K0165-01)   Matrix: Water   Sampled: 2022-10-31 10:20</b>			
<i>Radioactivity Parameters</i>			
Gross Alpha Activity	< 0.04	MAC = 0.5	0.04 Bq/L 2022-11-14
Gross Beta Activity	<b>0.08</b>	MAC = 1	0.03 Bq/L 2022-11-14

### 5.62 Rodeo Water System

			
TEST RESULTS			
REPORTED TO PROJECT	Summerland, District of Rodeo System	WORK ORDER REPORTED	22K0163 2022-11-14 13:04
Analyte	Result	Guideline	RL Units Analyzed Qualifier
<b>Lodge (22K0163-01)   Matrix: Water   Sampled: 2022-10-31 10:40</b>			
<i>Radioactivity Parameters</i>			
Gross Alpha Activity	< 0.10	MAC = 0.5	0.04 Bq/L 2022-11-14
Gross Beta Activity	<b>0.08</b>	MAC = 1	0.03 Bq/L 2022-11-14

## 5.7 Algae


Algae can be an indicator of water quality issues that could have an impact on water treatment processes such as filter clogging. Aesthetically, algae blooms can cause water discolouration, taste and odour. As a pre-emptive measure, samples were collected throughout the summer from five reservoirs including Thirsk, Headwaters #1, Isintok, Garnett Valley, Summerland and a sample from Trout Creek. These samples were submitted to Larratt Aquatic Consulting Ltd for analysis. There were no imminent water quality issues identified from the reservoirs in 2022.

### August 6<sup>th</sup> Samples

According to Larratt, the sample submitted from Thirsk had very high algae densities dominated by the diatom *Aulacoseira* sp. with 18170 cells /mL. Cyanobacteria were also present with 2070 cells/mL of mostly *Anacystis* sp. Cyanobacteria densities were slightly above the WHO Alert Level 1 threshold (2000 cells/mL). Larratt’s comments based on the densities observed on August 3<sup>rd</sup> suggest that this should not pose a risk for acute cyanotoxicity.

Headwaters #1 sample had moderate algae densities with 3190 total cells/mL that contained cyanobacteria (1310 cells/mL), diatoms (660 cells/mL) and green algae (640 cells/mL). Cyanobacteria densities were below the WHO Alert Level 1 threshold and should not pose a risk for acute cyanotoxicity.

Isintok sample contained very low algae densities of only 420 cells/mL.




## August 8<sup>th</sup> Samples

The sample from the *Garnett Irrigation Only System* contained very high cyanobacteria, driven by a bloom of *Anacystus* sp. and *Mircocystis* sp known to produce potentially toxic surface blooms. Total cell densities measured 20,790 cells/mL of which 14,830 cells/mL were cyanobacteria. This was the highest cell densities measured in Garnett Valley Reservoir to date. These samples were very high for a raw water sample but lower than expected to lead to acute cyanotoxicity.

The Summerland Reservoir contained a mixture of algae types, dominated by diatoms. Total cell densities measured 2810 cells/mL, with only 60 cells/mL being cyanobacteria. *Aulacoseira* sp. was the most common diatom that can reduce filtration efficiency. No health risks are expected from algae observed in the Summerland Reservoir sample.

The Trout Creek raw sample contained very low algae densities of 710 cells/mL primarily consisting of diatoms. No health risks are expected from algae observed in the Trout Creek Raw sample.



## 6.0 Annual Water Consumption

Gravity fed water from the Summerland reservoir supplies both the water treatment plant and the non-potable irrigation system. Two water meters located inside the building below the reservoir register daily consumption. The combined volume was approximately 7,529ML in 2022 with the minimum day demand on March 22<sup>nd</sup> at 2.273MLD and the maximum day demand on August 1<sup>st</sup> at 70.828MLD.

## 7.0 Water Quality Events

The DOS responded to five emergency water main breaks in 2022. The protocol for water main break response involves maintaining positive pressure in order to protect the water system from potential contamination. Challenges for maintaining water quality in the distribution system involved managing the preventative maintenance program while achieving target levels for infrastructure repair and replacement. Annual budget is allocated for the replacement of aging infrastructure.

### 7.1 Summerland Water System

A water main break occurred May 5<sup>th</sup> on Canyon View Road due to construction within the perpetual slide area. It was determined some debris entered the line and a boil water notice (BWN) was called for the area affecting 17 properties. A section of the mainline was removed and replaced as per AWWA protocol. Samples were taken on May 5<sup>th</sup> and May 6<sup>th</sup>. Due to high turbidity, another round of samples were taken on May 9<sup>th</sup>. Following three consecutive sets of negative bacteriological samples, the BWN was lifted with the approval of IHA.

SAMPLE DATE	LOCATION	CL2 RESIDUAL (ppm)	TURBIDITY (ntu)	TOTAL COLIFORMS	E-COLI
May 6/22	4007 Mountain Ave.	1.31	9.7	<1	<1
May 6/22	4208 Sherk St.	1.49	19.6	<1	<1
May 7/22	4333 Mountain Ave.	0.97	4.2	<1	<1
May 7/22	4208 Sherk St.	1.07	0.31	<1	<1
May 9/22	4333 Mountain Ave.	0.76	0.19	<1	<1
May 9/22	4208 Sherk St.	1.06	0.31	<1	<1

On May 18<sup>th</sup> another water main break occurred on Canyon View Road due to construction within the perpetual slide area. It was determined some debris entered the line and a boil water notice was called for the area affecting 17 properties. A section of the mainline was removed and replaced as per AWWA protocol. After disinfection of the new section of pipe and line flushing, there were two consecutive sets of bacteriological samples submitted to Caro Analytical. With approval from the IHA Drinking Water Officer, the BWN was rescinded on May 24<sup>th</sup>.

SAMPLE DATE	LOCATION	CL2 RESIDUAL (ppm)	TURBIDITY (ntu)	TOTAL COLIFORMS	E-COLI
May 19/22	4007 Mountain Ave.	1.17	0.90	<1	<1
May 19/22	4208 Sherk St.	1.34	0.64	<1	<1
May 20/22	4007 Mountain Ave.	0.85	0.82	<1	<1
May 20/22	4208 Sherk St.	1.02	0.30	<1	<1

On August 30<sup>th</sup> a water main break occurred on Giants Head Road. Works crews responded and determined that positive pressure was not maintained in the line and a BWN was called affecting 36 properties. After disinfection of the new section of pipe, there were two consecutive sets of bacteriological samples submitted to Caro Analytical. With approval from the IHA Drinking Water Officer, the BWN was rescinded on September 9<sup>th</sup>.



SAMPLE DATE	LOCATION	CL2 RESIDUAL (ppm)	TURBIDITY (ntu)	TOTAL COLIFORMS	E-COLI
Sept 2/22	12001 Giants Head Rd	1.10	0.87	<1	<1
Sept 2/22	11005 Giants Head Rd	0.22	0.21	<1	<1
Sept 2/22	10415 Giants Head Rd	1.18	0.32	<1	<1
Sept 6/22	12001 Giants Head Rd	1.13	0.18	<1	<1
Sept 6/22	11005 Giants Head Rd	0.23	0.22	<1	<1
Sept 6/22	10417 Giants Head Rd	1.26	0.31	<1	<1

A water main break occurred September 5<sup>th</sup> on Dale Meadows Road. It was determined debris entered the line and BWN was issued for 26 properties. After disinfection of the new section of pipe and line flushing, there were two consecutive sets of bacteriological samples submitted to Caro Analytical. With approval from the IHA Drinking Water Officer, the BWN was rescinded on September 9th.

SAMPLE DATE	LOCATION	CL2 RESIDUAL (ppm)	TURBIDITY (ntu)	TOTAL COLIFORMS	E-COLI
Sept 6/22	10316 Meadow View Estates	1.16	0.17	<1	<1
Sept 6/22	112-10903 Meadow View Estates	0.83	0.42	<1	<1
Sept 7/22	10316 10903 Meadow View Estates	1.12	0.15	<1	<1
Sept 7/22	112-10903 Meadow View Estates	0.64	0.16	<1	<1

A water main break occurred December 16<sup>th</sup> on Dale Meadows Road. It was determined that positive pressure was lost and a BWN was issued for 27 properties. After disinfection of the new section of pipe and line flushing, there were two consecutive sets of bacteriological samples submitted to Caro Analytical. Two more samples were collected from a property in a temporary dead end created by a closed isolation valve. With approval from IHA Drinking Water Officer, the BWN was rescinded on December 23<sup>rd</sup>.

SAMPLE DATE	LOCATION	CL2 RESIDUAL (ppm)	TURBIDITY (ntu)	TOTAL COLIFORMS	E-COLI
Dec 19/22	10316 Dale Meadows Place	1.15	0.22	<1	<1
Dec 19/22	112-10903 Meadow View Estates	1.27	0.36	<1	<1
Dec 20/22	10316 Dale Meadows Place	0.97	0.22	<1	<1
Dec 20/22	112-10903 Meadow View Estates	0.91	0.21	<1	<1
Dec 22/22	11505 Dale Meadows	0.39	1.06	<1	<1
Dec 23/22	11505 Dale Meadows	0.19	0.92	<1	<1

## **8.0 System Shortfalls and Problems**

### **8.1 Summerland Water System**

The large unprotected watershed is home to cattle farming, forestry practices and numerous recreational activities. The District will be working with the appropriate groups such as the Ministry of Forests, Lands, Natural Resource Operations and Rural Development towards production of a Source Protection Plan. The watershed is also subject to flooding, wildfires and drought conditions. High flow demands can exceed the capacity of the water treatment plant resulting in the supplemental line opening and allowing partially treated water into the system. This occurs rarely since the first phases of system separation were completed. To ensure that this risk is reduced, the District is continuing with plans to separate more sections of potable water distribution mains from irrigation only mains.

### **8.2 Rodeo Water System**

The Rodeo well is subject to low demand from late fall through early spring when the facility is at its lowest annual occupation rate. During this time, there is an increase in turbidity as well as iron concentration resulting in the potential for iron-forming bacteria. A continuously flowing flush line on the Lodge water connection continues to keep the well water turning over during the off-season low demand. A new water source is being investigated to eliminate the use of the Rodeo well system.

## **9.0 Capital Works Plan**

### **9.1 Completed Projects in 2022**

#### **Water Treatment Plant**

- Rotork Actuator installation on both raw water valves, filter to waste valves and filter backwash valves
- Emergency coagulant storage tanks
- Text capable WTP Auto-dialer

#### **Watershed**

- Isintok Dam outlet pipe replacement & slope protection – Construction
- Isintok Dam Driftwood/Tree Removal

#### **Water Distribution System**

- PRV# 14 above ground upgrade – Construction
- PRV #4 Above ground upgrade – Design
- Canyon View road water main replacement
- Trout Creek Flume & Water Intake Structure Upgrade – Design
- Giants Head Water Separation – Design

### **9.2 Anticipated Capital Projects for 2023**

#### **Water Treatment Plant**

- WTP Controls Upgrade & PLC Upgrade – Design

#### **Watershed**

- Source Water Assessment
- Isintok Dam Spillway - Design
- Thirsk Dam structure analysis continued
- Dam Safety Review – Crescent and Whitehead
- Isintok Dam Spillway Design

#### **Water Distribution System**

- PRV #4 Above ground upgrade – Construction
- PRV #7 Above ground upgrade – Design & Construction
- Auxiliary Power to Pump Station #5 – Design
- Giants Head Road Water System Separation – Construction
- System Separation Study
- Jubilee Road water main (Rosedale and Victoria)
- Trout Creek Intake Turbidity Meter
- Cathodic Protection Upgrades
- Dale Meadows water main replacement Design and Construction

### 9.3 Future Capital Projects

The following is a projection of future capital projects over the next five years:

Project	2024	2025	2026	2027	2028
WTP Controls Upgrade - Construction	X				
Actiflo #1 and Actiflo #2 Lamella Block Replacements	X	X			
Chlorine gas to sodium hypochlorite conversion	X	X			
Isintok Dam Spillway –Construction		X			
Crescent Dam Outlet & Spillway – Design & Construction				X	X
Auxiliary Power to Pump Station #5 - Construction	X				
Auxiliary Power to Pump houses #2 and #6		X	X	X	X
Trout Creek Flume & Water Intake Structure upgrade – Construction (Grant Dependent)					X
Garnet Dam spillway widening, slope protection & apron extension - Design			X	X	
Annual Water Main Replacements	X	X	X		
Dale Meadows water main replacement	X				
Thirsk Slide Gates Replacement		X	X		
PRV #1 and Trout Creek Tank above ground upgrades		X	X		
Source Water Protection Plan	X				

## **10.0 Emergency Response Plan**

The DOS Water division has produced a new Emergency Response Plan in 2022 that will be updated annually or as required. This document is available for viewing at the Public Works office and the Water Treatment Plant. An electronic copy is available on the District of Summerland website.

## **11.0 Cross Connection Control (CCC)**

The DOS has a certified CCC inspector on staff who tests all municipally owned backflow assemblies. The town currently tests and tracks approximately 65 backflow assembly devices located on District owned and/or operated facilities. The District also currently tracks 418 backflow assemblies in our backflow management program.

### **11.1 CCC Bylaw 2358**

A bylaw is in place to ensure the installation of proper backflow devices in all new construction. The District of Summerland retained MTS Inc. in 2022 to work in conjunction with the District's Certified CCC Tester to ensure appropriate CCC services. All new houses and construction projects in the DOS must now have a minimum double check installed.

## **12.0 Supervisory Control and Data Acquisition (SCADA)**

The Summerland water system utilizes a SCADA system for gathering and analyzing real time data. The data collected is used to monitor and control the plant processes, detect and correct problems, and measure trends over time. Trending is then utilized to maintain efficiency, process data and communicate system issues in order to prevent unnecessary operational downtime.

The components of the SCADA system include sensors and control relays, Remote Telemetry Units referred to as RTUs, a SCADA master unit, and the communication network. The system includes input and output signal hardware, networks, a Human-Machine Interface or HMI, controllers, communication, a database, and software.

Most of the control functions performed by the SCADA system are done automatically by two types of devices, either RTUs – Remote Terminal Units or PLCs - Programmable Logic Controllers. Data such as equipment status, meter readings and alarm status are collected at the RTU or PLC level.

The HMI serves as the master station that communicates the process status and alarm information collected along the SCADA system to the human operator. The pieces of data from the system are gathered into this one place, saving operators from manually combining polled data from individual points.

Operators are able to view any system alarms and information through the HMI, and make educated decisions based on the readings. The system is equipped with control functions so signals can be sent back to the RTUs to execute certain actions.

## **12.1 SCADA Updates**

The following updates occurred in 2022:

- Added temperature trending for the Raw Water pumps
- Improved Turbidity & Filter level trending
- Supplemental Line activation switch
- Added 2 Dam sites to Scada monitoring; Thirsk and Garnett trending

## **12.2 Future SCADA Updates**

- Design for PLC & SCADA upgrade in mid 2023 with construction to start in late 2023
- Distribution systems are adding/upgrading remote monitoring at specific pump stations and pressure reducing stations to improve communication.