



SCHEDULE "H"

RESIDENTIAL UNDERGROUND IRRIGATION WATER USERS
EXCESS WATER APPLICATION

Director of Engineering and Public Works
District of Summerland
Box 159, 9215 Cedar Avenue
Summerland, BC V0H 1Z0

Name
Roll No.
Civic Address
or Lot(s) Block DL Plan
Arable Acres

Dear Sir:

Whereas Section 7.4 of Bylaw No. 2358 restricts the allocation of water for irrigation purposes to a maximum combined flow of twenty-seven (27) litres (6 Imperial gallons or 7.2 US gallons) per minute per arable acre or 0.45 hectares;

Excess water will be permitted provided applicant meets these requirements for underground Irrigation Systems:

- 1. Install an approved dual check valve;
2. 10 gallon per minute flow control valve;
3. System must be on a time clock;
4. Connection to line must be inside house (residential);
5. Hours of operation from 12:00 a.m. to 6:00 a.m.;
6. Plans must be submitted - colour code zones;
7. Any additions or changes to your system will require a new application.

The District of Summerland reserves the right to cancel this application at any time without notice for reasons of water shortage or abuse of irrigation procedures by the Applicant.

I hereby understand and agree with the above:

Owner/Customer/Water User

Approved, 20.
on behalf of the District of Summerland

Address

Director of Engineering and Public Works

(Installed by)

Inspected, 20.
by