

ADDENDUM NO. 1
to the
Request for Quotation
for
Paving Program 2018

To all Bidders:

October 30, 2018

The following changes, additions, and/or deletions are hereby made a part of the Contract Documents for the District of Summerland, Paving Program 2018:

Question: Item #1 mentions Bonding. Is there any required?

Answer: No bonding will be required for this RFQ

Question: Will the contractor be responsible to excavate 150mm deep to allow for base material?

Answer: Depending on site conditions, with the District's authorization, if sufficient base materials exist, the contractor may be allowed to eliminate this item or reduce the excavation depth.

Question: Would an Integral curb not 150mm high but stronger be acceptable on Doherty Ave?

Answer: Yes

Question: Would reclaiming be an option for asphalt removal?

Answer: If reclaiming the asphalt is financially beneficial to the District, reclaiming asphalt may be used as an alternative to the scope of works.

Question: If the contractor mills the asphalt does the District want the millings?


Answer: The District will take the millings if a District representative determines they are of a high enough quality to be used for intended projects.

Question: Is there any design completed for the roads?

Answer: The only designs are the plans showing paving limits provided on the RFQ. PDF and AutoCAD files of these plans can be provided to the successful bidder.

All Bidders shall acknowledge receipt and acceptance of this Addendum by initialing each page in the space provided and submitting the initialed addendum with the bid. Bids submitted without this Addendum may be considered incomplete.

Yours truly,

A handwritten signature in black ink, appearing to read "Jm", with a long horizontal stroke extending to the right.

Jake McAstocker
Engineering Technologist