

---

**ADDENDUM NO. 1**  
to the  
**Contract Documents**  
for  
**Wastewater Treatment Plant HVAC Replacement**

To all Bidders:


September 13, 2018

The following changes, additions, and/or deletions are hereby made a part of the Contract Documents for the District of Summerland, Wastewater Treatment Plant HVAC Replacement:

1. Reference mechanical drawings M1.01 and M2.01. The new HVAC equipment, RTU-1, HRV-1 and HRV-2 are to be connected to, controlled and monitored by the existing building automation and control system provided and serviced by Care Systems Services Ltd. (250) 558-5409.

All Bidders shall acknowledge receipt and acceptance of this Addendum by initialing each page in the space provided and submitting the initialed addendum with the bid. Bids submitted without this Addendum may be considered incomplete.

Yours truly,

A handwritten signature in black ink, appearing to be "Devon", with a long horizontal line extending to the right.

Devon van der Meulen  
Manager of Utilities

Bidders Initial: \_\_\_\_\_