



ADDENDUM NO. 2

DATE ISSUED: December 11, 2018

PROJECT: RFQ-2018-15 – Powerline Vegetation Management

The Request for Quotation documents for this work are revised as noted herein. All such revisions become a part of the work and shall be included in your Quotation. No consideration will be allowed for extras due to the Contractor not being familiar with this addendum.

1. Reference: Answers to Questions Received

The following are answers to questions received:

Q1	Does Schedule 'A' - Scope of Work include brushing (i.e. slashing removal) of tall growing species to the contract-specified distance of 3m or is the scope of work only to prune the vegetation to 3m from primary and secondary lines?
A1	The scope is to prune the vegetation 3m from the primary and secondary lines.
Q2	What overheight clearance is required above primary conductors?
A2	There is a 3m clearance required on all sides of primary conductors.
Q3	For non-target species and any trees that are not being removed that are growing under the lines, how low does this vegetation need to be reduced below the lowest secondary lines?
A3	Trees or vegetation growing under the lines that are not being removed require a 3m clearance below the lowest secondary lines.

END OF ADDENDUM NO. 2